

Frenchtown Water PFAS Drinking Water Report



Date Collected	Sampling Location	PFOS + PFOA Parts Per Trillion (ppt)	EPA Lifetime Health Advisory Level PFOS+PFOA	Total Tested PFAS (ppt)
4/29/2019	Finished Water	Not Detected	70 ppt	Not Detected
4/29/2019	Finished Water	Not Detected	70 ppt	Not Detected
5/28/2019	Finished Water	Not Detected	70 ppt	2 ppt
6/24/2019	Finished Water	Not Detected	70 ppt	Not Detected
7/30/2019	Finished Water	Not Detected	70 ppt	3 ppt
9/3/2019	Finished Water	10 ppt	70 ppt	14 ppt
9/3/2019	Finished Water	8 ppt	70 ppt	12 ppt
9/4/2019	Finished Water	11 ppt	70 ppt	16 ppt
9/4/2019	Finished Water	15 ppt	70 ppt	22 ppt
9/5/2019	Finished Water	10 ppt	70 ppt	14 ppt
9/5/2019	Finished Water	8 ppt	70 ppt	15 ppt
9/6/2019	Finished Water	8 ppt	70 ppt	12 ppt
9/6/2019	Finished Water	9 ppt	70 ppt	13 ppt

ppt- Parts Per Trillion

EPA - Environmental Protection Agency

LHA-Lifetime Health Advisor Level

EPA LHA 70 ppt

PFOS - perfluorooctane sulfonic acid

PFOA - perfluorooctane acid

PFAS - per-and polyfluoralkyl substances